

## SWIMMING POOL Checklist

Address:

Consent number:

Inspectors name:

Date:

8:00am	10:00am	1:00pm	3:00pm	Pass	Fail

Partial	Full

**Fence**

	Yes	No
Is the height 1200mm or greater		
Is the max ground clearance less than 100mm		
Are all gaps less than 100mm		
Are all horizontal rails on pool side		
Are all horizontal rails 900mm or greater apart		
Is the trellis/mesh less than 10mm		
Is the fence at least 1200mm away from projections		
Is the fence free from climb points		
If latch on pool side of gate, is it 1200mm above ground level		
If latch outside pool, is it 1500mm above ground level		
Does gate open outward from pool.		
Is the gate self closing and self latching when released from 150mm in the open position.		
<b>Immediate pool area</b>		
Is the pool and other permitted items such as barbeque and pool equipment etc the only features within the pool enclosure		
Is there an area available for children to play other than in the pool enclosure		
Does the enclosed pool area form a cul-de-sac ie: do you have to access other areas through pool area such as gardens, play areas, garage etc.		
Are all doors self closing and self latching (1500mm from closed position).		
Are door handles, latches 1500mm or more above floor.		
Are 100mm restricters fitted to all opening windows with a sill height less than 1200mm		
Is all access to top surface of all fences and walls (retaining) restricted to prevent children walking upon		
Are any gates and their latches at least 1200mm away from any stairs/ ramps that maybe considered as climb points reducing the latch height		
Have all trees/shrubs been cut back to 1200mm from fence, eliminating possible climb points		
If pool barrier is a boundary fence have all measures been taken to prevent climb points from such matters as heaps firewood, in built bar-b-ques, etc on the adjacent property		
Have you completed a full walk around the fence perimeter and reviewed all components		

**Comments**

