

Appendix G: Summary of Australian Standard *AS 2560 Guide to Sports Lighting*

From AS 2560.2.1:2003 recommended average maintained illuminance levels for Tennis (Extract from Table 1)

Level of Play	Horizontal Illuminance (lux)	Uniformity U1 Min/Avg
Training, Recreation	250	0.6
Club Competition	350	0.6

From AS 2560.2.3:2007 recommended average maintained illuminance levels for Football (all codes i.e. football, rugby league and rugby union), (Extract from Table 1)

Level of Play	Horizontal Illuminance (lux)	Uniformity U1 Min/Avg	Uniformity U2 Min/Max
Level 1 - Ball & Physical Training	50	0.3	N/A
Level 2 - Match Practice	100	0.5	0.3
Level 3 - Competition	200	0.6	0.4

From AS 2560.2.4:1986 recommended average maintained illuminance levels for Outdoor Netball and Basketball, (Extract from Table 1)

Level of Play	Horizontal Illuminance (lux)	Uniformity U1 Min/Avg
Recreation & Training	100	0.5
Competition	200	0.66

From AS 2560.2.7:1994 recommended average maintained illuminance levels for Hockey, (Extract from Table 1)

Level of Play	Horizontal Illuminance (lux)	Uniformity U1 Min/Avg
Physical Training	30	0.25
Ball Training, Junior and Minor Club Competition	250	0.6
Major Club, National and International Competition	500	0.7